



# Holy Cross College (Autonomous) Nagercoil – 629 004

Affiliated to Manonmaniam Sundaranar University, Tirunelveli  
Nationally Accredited with A+ Grade (CGPA 3.35) by NAAC IV Cycle  
An ISO 9001:2015 Certified Institution

SSR  
2019-2020  
to  
2023-2024

## 6.5.3 Quality audit reports/certificate

6638  
20/12/2023

TAMIL NADU FIRE – RESCUE SERVICE  
FIRE –LICENSE  
(See Section 13)

L.Dis.No: 10165/ A / 2023

Date: 15.12.2023

License is hereby granted under section 13 of the Tamil Nadu Fire Service Act. 1985 to for Running College in the name of "M/s. Holy Cross College" within the Jurisdiction Agastheeswaram Taluk the Premises Door No: K1/2/5,6,4,7,9,10,11(Pt), K1/3/4(Pt), 5,10,3,7,8,9,11,12, K1/21/1, 22(Pt),3,4,5(Pt), 9(Pt), 3(Pt), 14, K1/23/1,2,5, K1/22/1 of Neendakarai "A" Village, Nagercoil Corporation, Agastheeswaram Taluk, Kanyakumari District. Subject to the Condition noted thereon and such other condition as may be prescribed.


The above Building is inspected by Kanyakumari Asst. District Officer T.Immanuel on 15.12.2023.

This Fire License is valid for one year from the date of issue of this license.


### CONDITIONS:

- 1) The Installed Fire Fighting Equipment's should be maintained in good condition at all times.
- 2) All exits should be free of obstructions. Exits should be clearly visible and the routes to reach the exit shall be clearly marked.
- 3) As per Tamil Nadu Combined building development Rules-2019 Setback area of all around the Building and other rules should be followed otherwise regularization of the deviated building should be obtained approval within six months from competent authority (DTCP).
- 4) Trained Fire personnel should be available to operate the Fire Fighting Equipment's in case of any emergency
- 5) "Mock Drill Should be conducted periodically and the date of conduction should be informed to this office well in advance to enable the team to make suggestions if any
- 6) Dumping of waste materials anywhere should be avoided. Dust bin should be cleared frequently
- 7) Any erection of permanent or temporary structure should be intimated to this department.
- 8) Do's Don'ts in time of emergencies should be available in a laminated hanging card.
- 9) Plan Approval Should be obtained from the competent authority.
- 10) As per approved plan requirements side set back clear area should be Maintained without any obstruction.
- 11) In Compliance to section 3.2 of BIS 12459:1988-code of practice for fire safety in cable regularization, a transparent fire-retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.

Office Seal with Date



To The Principal,  
M/s. Holy Cross College,  
Nagercoil,  
Kanyakumari District. 629 004.

  
District Officer  
Fire & Rescue Services  
Kanyakumari District, Nagercoil

8376  
17/11/2022

TAMIL NADU FIRE - RESCUE SERVICE  
FIRE -LICENSE  
(See Section 13)

L.Dis.No: 7746/ A / 2022

Date : 10.11.2022

Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act, 1985 to for Running College in the name of "M/s. Holy Cross College" within the Jurisdiction Agastheeswaram Taluk the Premises Door No: K1/2/5,6,4,7,9,10,11(Pt), K1/3/4(Pt), 5,10,3,7,8,9,11,12, K1/21/1, 22(Pt),3,4,5(Pt), 9(Pt), 3(Pt), 14, K1/23/1,2,5, K1/22/1 of Neendakarai "A" Village, Nagercoil Corporation, Agastheeswaram Taluk, Kanyakumari District. Subject to the Condition noted thereon and such other condition as may be prescribed.

The above Building is inspected by Kanyakumari Asst.District Officer S.Jeevans on 08.11.2022.

This Fire Licence is valid for one year from the date of issue of this license.

CONDITIONS:

- 1) *The Installed Fire Fighting Equipments should be maintained in good condition at all times.*
- 2) *All exits should be free of obstructions. Exits should be clearly visible and the routes to reach the exit shall be clearly marked.*
- 3) *Trained Fire personnel should be available to operate the Fire Fighting Equipments in case of any emergency*
- 4) *"Mock Drill Should be conducted periodically and the date of conduction should be informed to this office well in advance to enable the team to make suggestions if any*
- 5) *Dumping of waste materials anywhere should be avoided. Dust bin should be cleared frequently*
- 6) *Any erection of permanent or temporary structure should be intimated to this department.*
- 7) *Do s Don'ts in time of emergencies should be available in a laminated hanging card.*
- 8) *Plan Approval Should be obtained from the competent authority.*
- 9) *As per approved plan requirements side set back clear area should be Maintained without any obstruction.*
- 10) *In Compliance to section 3.2 of BIS 12459:1988-code of practice for fire safety in cable regularization, a transparent fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.*

Office Seal with Date



District Officer  
Fire & Rescue Services  
Tirunelveli District.  
(F.C) Kanyakumari District, Nagercoil

To The Principal,  
M/s. Holy Cross College,  
Nagercoil,  
Kanyakumari District. 629 004.



31/05  
27/11/2021

TAMIL NADU FIRE – RESCUE SERVICE  
FIRE –LICENSE

(See Section 13)

L.Dis.No: 7288/ A / 2021

Date : 23 . 11, 2021

Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act. 1985 to for Running College in the name of "M/s. Holy Cross College" within the Jurisdiction Agastheeswaram Taluk the Premises Door No: K1/2/5,6,4,7,9,10,11(Pt), K1/3/4(Pt), 5,10,3,7,8,9,11,12, K1/21/1, 22(Pt),3,4,5(Pt), 9(Pt), 3(Pt), 14, K1/23/1,2,5, K1/22/1 of Neendakarai "A" Village, Nagercoil Corporation, Agastheeswaram Taluk, Kanyakumari District. Subject to the Condition noted thereon and such other condition as may be prescribed.

This Fire Licence is valid for one year from the date of issue of this license.

CONDITIONS:

- 1) *The Installed Fire Fighting Equipments should be maintained in good condition at all times.*
- 2) *All exits should be free of obstructions. Exits should be clearly visible and the routes to reach the exit shall be clearly marked.*
- 3) *Trained Fire personnel should be available to operate the Fire Fighting Equipments in case of any emergency*
- 4) *"Mock Drill Should be conducted periodically and the date of conduction should be informed to this office well in advance to enable the team to make suggestions if any*
- 5) *Dumping of waste materials anywhere should be avoided. Dust bin should be cleared frequently*
- 6) *Any erection of permanent or temporary structure should be intimated to this department.*
- 7) *Do s Don'ts in time of emergencies should be available in a laminated hanging card.*
- 8) *Plan Approval Should be obtained from the competent authority.*
- 9) *As per approved plan requirements side set back clear area should be Maintained without any obstruction.*

Office Seal with Date



*[Signature]*  
District Officer  
Fire & Rescue Services  
Kanyakumari District, Nagercoil

To The Principal,  
M/s. Holy Cross College,  
Nagercoil,  
Kanyakumari District. 629 004.



**FORM -D**

Form of License Under Sub – section 6 of the Tamil Nadu Public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 6 of the Tamil Nadu Public Buildings, (Licensing) rules 1966.

**LICENSE**

License No. **22/2020**  
Registration No. K.Dis.(C2)/6299/2019

Fees Rs. 30000/-  
(Rupees Thirty Thousand Only)

License is here by granted to the **Secretary, Holy Cross College, (Autonomous) Nagercoil, Neendakari A East Village in Agasteeswaram Taluk, Kanniyakumari District** for the purpose and in respect of the Building specified in the statement below and subject to the condition and for the period mentioned there under. The period of validity of the License shall be from **01.06.2018 to 31.05.2021**.

Tahsildar  
Agasteeswaram  
04/03/2020

**STATEMENT ACCOMPANYING THE LICENSE**

Location of the Building (D.No. street No. and Name of place )	Purpose for which the Building is License to be used	No. of persons to be Accommodated as reported by the Panel Engineer
Cecile Hall,	Educational Purpose	100 Nos
Claudin Block		1000 Nos
Hostel Building(Block -I)		200 Nos
Hostel Building(Block -II)		200 Nos
Indoor Stadium		100 Nos
Library		200 Nos
Main Building		1500 Nos
Mermine Block		500 Nos
Multipurpose Hall .		1500 Nos
St.Joseph's Block		500 Nos
Golden Jubilee Building		1500 Nos

Date: 04.03.2020.

Tahsildar  
Agasteeswaram  
04/03/2020



2462  
6/6/19

TAMIL NADU FIRE – RESCUE SERVICE  
FIRE –LICENSE  
(See Section 13)

L.Dis.No: 2326/ A / 2019

Date : 24. 05.2019


Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act. 1985 to for Running College in the name of "M/s. Holy Cross College" within the Jurisdiction Agastheeswaram Taluk at the Premises Sy.No: K1/2/5,6,4,7,9,10,11(Pt), K1/3/4(Pt),5,10,3,7,8,9,11,12, K1/21/1,22(Pt),3,4,5(Pt), 9(Pt), 3(Pt), 14, K1/23/1,2,5,K1/22/1 of Neendakarai "A" Village, Nagercoil Municipality, Agastheeswaram Taluk, Kanyakumari District. Subject to the Condition noted thereon and such other condition as may be prescribed.

This Fire Licence is valid for one year from the date of issue of this license.

CONDITIONS:

- 1) *The Installed Fire Fighting Equipments should be maintained in good condition at all times. In Additional ABC 4Kg-15 Nos, Co2 2Kg-10Nos, & Co2 4.5Kg-10 Nos of Fire Extinguishers should be installed.*
- 2) *Hose Reel System Should be installed with in Three Month.*
- 3) *All exits should be free of obstructions. Exits should be clearly visible and the routes to reach the exit shall be clearly marked.*
- 4) *Trained Fire personnel should be available to operate the Fire Fighting Equipments in case of any emergency*
- 5) *"Mock Drill Should be conducted periodically and the date of conduction should be informed to this office well in advance to enable the team to make suggestions if any*
- 6) *Dumping of waste materials anywhere should be avoided. Dust bin should be cleared frequently*
- 7) *Any erection of permanent or temporary structure should be intimated to this department.*
- 8) *Do s Don'ts in time of emergencies should be available in a laminated hanging card.*

Office Seal with Date

  
District Officer  
Fire & Rescue Services  
Kanyakumari District, Nagercoil

To The Principal,  
M/s.Holy Cross College,  
Roach Nager  
Kurusady,

